



FIRE SAFETY CERTIFICATE

Certified that **Ramjas School, Sector-4, R.K.Puram New Delhi-110022**, comprised of ground plus one upper floor owned / occupied by Ramjas School was earlier issued FSC vide letter No. F6/DFS/MS/School/2022/1328 dated 14/12/2022. Now The said premises was re- inspected by the officer concerned of this department on 29/10/2025 in the presence of Mrs. Richa Sharma (Principal) of the school and found that the said school building has deemed complied with the fire prevention and fire safety requirements in accordance with Director of Education Circular dated 01/03/2011 and that the building is fit for occupancy class "**Educational Building Group- B**" with effect from 13/11/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 13/11/2025 at New Delhi by.

Uma

Richa

PRINCIPAL

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service
O/C @

Copy to:-

1. The Director of Education, Govt.of NCT of Delhi, Old Secretariat, New Delhi-110054
SECTOR-IV, R.K. PURAM
NEW DELHI-110022
2. The Principal, Ramjas School, at Sector-4 R.K. Puram, New Delhi-110022

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.