

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No.F.6 DFS MS School 2022 SZ-1328

Dated: 14/12/2022

FIRE SAFETY CERTIFICATE

Certified that Ramjas School, located at Sector- IV, R.K Puram, New Delhi 110022 Comprised of Ground plus one upper floor, owned/occupied by Ramjas School, was issued Fire Safety Certificate by this department vide letter no. F6 DFS/MS/School/2019/SZ/1611 Dt. 13/08/2019. The said premises was re-inspected by officer concerned of this department on 01/12/2022 in presence of Mr. Rajender Uniyal of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16 Estate CC Fire Safety/2011-3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational Building Group - B" (School) with effect from 14/12/2022 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 14/12/2022 at New Delhi by

(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. The Principal, Ramjas School, located at Sector- IV, R.K Puram, New Delhi 110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape entry exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used as per the provisions of BBL/NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhi.govt.nic.in](http://www.dfs.delhi.govt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

MANAGER  
RAMJAS INTERNATIONAL SCHOOL  
SECTOR-IV, R. K. PURAM  
NEW DELHI-110022

PRINCIPAL  
RAMJAS INTERNATIONAL SCHOOL  
SECTOR-IV, R.K. PURAM  
NEW DELHI-110022